



## Pharmaceutical Process Control

Application

Pharmaceutical  
 Chemical  
 Departments  
 • Research  
 • Production  
 21 CFR Part 11 Compliance

### Overview

Pharmaceutical products are produced under carefully controlled conditions to ensure product quality. Each process is different and requires close attention to detail. Sterilization, fermentation, extraction, neutralization, filtering, freeze drying, and centrifuging are typical processes found in this industry.

### Challenge

The development of new medicines requires a variety of measurements in several different processes. The instrument used must be accurate and flexible enough to accommodate these demands. In some cases, the instrument may need to control a portion of the process while it measures the results.

### Solution

A VXIbus data acquisition and control system from VXI Technology makes an excellent process evaluation tool for users in the pharmaceutical industry. Accurate monitoring and precise control ensures that a new process is tested thoroughly. By characterizing the process, production costs can be lowered and product quality can be improved. A standard commercial graphical programming language and computer offer easy operator interfacing, data analysis, storage, and report generation.

### Implementation

#### Process Temperature

Temperature is an important measurement in most pharmaceutical processes. Often, temperature is used to control the speed of a chemical reaction. Thermocouples, RTDs, or thermistors are used with a data acquisition instrument to measure process temperatures. The data acquisition instrument can control heaters or chillers to change temperature in the process.

#### Process Pressures, Pump Control, and Valve Control

In some processes, maintaining proper pressure is crucial to obtaining the correct chemical reaction. Pressure transducers usually output a voltage or current proportional to pressure. Pressure can be controlled by actuating pumps and valves.

# Pharmaceutical Process Control



## Process Flows

Some processes are continuous and require a certain flow rate to be maintained for one or more chemicals entering the reactor vessel. Flow meters (analog output or pulse train output) can be used for monitoring. Digital-to-analog converters control flow rate by setting proportional valve position.

## Chemical Composition

The density of ions like bromide, calcium, chloride, fluoride, nitrate, sodium, and sulfide can be measured with transducers. The acidity (pH) may also be important in the process. With careful monitoring and control over the amounts of chemicals entering a process, the correct chemical composition can be maintained.

## Tank Level

To reduce costs, proper liquid levels in tanks must be controlled throughout the process. Excessive levels require extra chemicals while diminished levels could result in improper chemical composition. Both digital (point level sense) and analog (continuous level sense) techniques are commonly used.

## Agitator Control

An agitator is used to mix solids, liquids, or gases thoroughly. Shaft encoders can be used to monitor the speed of the agitator while torque transducers can be used to monitor the consistency of the product being agitated.

## Product Weight

Solids can be accurately measured by weight using load cells which provide a linear voltage output or bridge output that can be measured by the data acquisition system.

### Key System Features

### Typical Configuration

	Data Acquisition System	Quantity
VXIbus open architecture	CT-100C VXI 6-Slot Card Cage	1
Data Acquisition and Control on a single programmable VXIbus card (VT1419A)	FireWire VXI Slot 0 Command Module	1
Graphical programming language (Agilent VEE or NI Labview)	VT1419A Multifunction Measurement & Control Card	1-3
Flexibility with deterministic control	Analog input channels (VT1503A)	40-100
Wide choice of inputs/outputs	Strain gage completion channels (VT1506A)	1-5
Built-in control algorithms	Counters channels (VT1538A)	2-10
Up to 32 user-written "C" code algorithms	Voltage DAC channels (VT1531A)	8-16
65,000 reading FIFO buffer	Pulse output channels (VT1538A)	1-5
500 reading Current Value Table(CVT)	Digital input channels (VT1533A)	16-32
All algorithms can write to FIFO/CVT	Digital output channels (VT1533A)	20-60
Data can be time-stamped		